

=====

AVAILABILITY

Service is available under this rider at points on the Cooperative's existing electric distribution system, located within its service area, for Customers operating Renewable Energy Resources. The service is available to Customer-generators on a first-come, first-served basis until the total rated generating capability of all interconnections under this rider equals or exceeds four percent of the Cooperative's peak load for the previous calendar year. Upon reaching this limit, no further service shall be available under this rider. This rider shall not be available for any electric service schedule allowing for resale. A qualifying Customer-generator shall have the alternative option of interconnecting renewable generation under the Cooperative's Net Metering Rider. However, renewable Customer-generators may not change between the net metering and parallel generation riders without the prior approval of the Cooperative, and such elections shall not be for periods less than one year.

APPLICABILITY

This rider is applicable to Customer-generators with a Cooperative-approved interconnection agreement that are taking service under one of the Cooperative's normal rate schedules. This rider is not applicable where the nameplate capability of the Customer's electrical generating system exceeds 25 kilowatts for residential customers or 200 kilowatts for commercial customers.

CHARACTER OF SERVICE


Alternating current, 60 cycles, at the voltage and phase of the Cooperative's established secondary distribution system immediately adjacent to the service location.

BILLING AND PAYMENT

The Cooperative shall render a bill for consumption at approximately 30-day intervals during the Cooperative's normal billing process. Billing by the Cooperative to the Customer shall be in accordance with the applicable rate schedule.

=====

Officer



Title

PRESIDENT

For Bills Rendered on or after April 1, 2024

Replacing Schedule 20 – PGS – R

For electrical energy generated that exceeds the Customer's instantaneous load and delivered by the Customer to the Cooperative from the Customer's Qualifying Facility not in excess of the appropriate generator sizing (load), the Cooperative shall pay one-hundred fifty percent (150%) of the Cooperative's actual cost of purchased energy and fossil fuel burned in generation as calculated in the Power Cost Adjustment (PCA) filing for the period(s) in which energy was delivered to the Cooperative. At Cooperative's discretion, such amount shall be credited to Customer's account or paid at least annually.

Any electric energy generated that exceeds the Customer's instantaneous load and delivered by the Customer to the Cooperative from the Customer's Qualifying Facility in excess of the appropriate generator sizing (load), the Cooperative may, at its sole discretion, pay one-hundred fifty percent (150%) of the Cooperative's actual cost of purchased energy and fossil fuel burned in generation as calculated in the Power Cost Adjustment (PCA) filing for the period(s) in which energy was delivered to the Cooperative. At Cooperative's discretion, such amount shall be credited to Customer's account or paid at least annually.


DEFINITIONS

Customer-generator:

The owner or operator of a qualified electric energy generation unit which:

- (a) Is powered by a Renewable Energy Resource as defined by Kansas state statutes (see definition below);
- (b) Has an electrical generating capacity of 25 kilowatts or less for residential customers or 200 kilowatts or less for commercial customers;
- (c) Is located on a premises owned, operated, leased, or otherwise controlled by the Customer-generator;
- (d) Is interconnected and operates in parallel phase and synchronization with the Cooperative;
- (e) Is appropriately sized for the Customer-generator's anticipated electric load;
- (f) Meets all applicable safety, performance, interconnection, and reliability standards established by the National Electrical Code, the National Electrical Safety Code, the Institute of Electrical and Electronics Engineers, Underwriters Laboratories, the Federal Energy Regulatory Commission, and any local governing authorities; and

Officer



Title

PRESIDENT

For Bills Rendered on or after April 1, 2024

Replacing Schedule 20 -- PGS -- R

- (g) Contains a mechanism that automatically disables the unit and interrupts the flow of electricity back onto the Cooperative's electric lines in the event that service to the Customer-generator is interrupted.

Each meter connected under this rider defines a Customer-generator. A generator owned or operated by a Customer-generator cannot be connected in common with any other meter or be deemed to be for the purpose of serving the load connected to any other meter. To the extent that the Customer-generator controls the Renewable Energy Resources and meets the requirements and accepts all of the obligations of this rider, the Customer-generator is not required to own the generating facilities.

Renewable Energy Resources:

Electrical energy produced from an energy resource or technologies defined as renewable in K.S.A. 17-4652, and amendments thereto, and energy produced from municipal or other solid waste and animal waste.

Peak load:

The one-hour maximum annual demand imposed by the Cooperative's retail load applicable to the territory to which this schedule is applicable.

TERMS AND CONDITIONS

1. The Cooperative will supply, own and maintain at its expense all necessary meters and associated equipment utilized for billing. In addition, and for purposes of monitoring Customer generation and load, the Cooperative may install load research metering at its expense. The Customer shall supply, at no expense to the Cooperative, a suitable location for meters and associated equipment used for billing and for load research. Such equipment shall be accessible at all times to Cooperative personnel.
2. The Cooperative shall have the right to require the Customer, at certain times and as electric operating conditions warrant, to limit the production of electrical energy from the generating

Officer



Title

PRESIDENT

For Bills Rendered on or after April 1, 2024

Replacing Schedule 20 – PGS – R


=====

facility to an amount no greater than the load at the Customer's facility of which the generating facility is a part.

3. The Customer shall furnish, install, operate and maintain in good order and repair without cost to the Cooperative such relays, locks and seals, breakers, automatic synchronizers, disconnecting devices, and other control and protective devices as shall be designated by the Cooperative as being required as suitable for the operation of the generator in parallel with the Cooperative's system.
4. The Customer shall install and maintain a visible, manual disconnect switch. This manual switch must have the capability to be locked out by Cooperative personnel to isolate the Cooperative's facilities in the event of an electrical outage on the Cooperative's transmission and distribution facilities serving the Customer. This isolating device shall also serve as a means of isolation for the Customer's equipment during any Customer maintenance activities, routine outages or emergencies. The Cooperative shall give notice to the Customer before a manual switch is locked or an isolating device used, if possible; and otherwise shall give notice as soon as practicable after locking or isolating the Customer's facilities.
5. The Customer shall reimburse the Cooperative for any equipment, facilities, protective equipment or upgrades required solely as a result of the installation by the Customer of generation in parallel with the Cooperative's system.
6. The Customer shall notify the Cooperative prior to the initial energizing and start-up testing of the Customer- owned generator, and the Cooperative shall have the right to have a representative present at said test.
7. If harmonics, voltage fluctuations, or other disruptive problems on the Cooperative's system are directly attributable to the operation of the Customer's system, such problem(s) shall be corrected at the Customer's expense.

=====

Officer



Title

PRESIDENT

For Bills Rendered on or after April 1, 2024

Replacing Schedule 20 – PGS – R

- =====
8. No Customer's generating system shall damage the Cooperative's system or equipment or present an undue hazard to Cooperative personnel. The Cooperative shall not be liable directly or indirectly for permitting or continuing to allow an attachment of a Customer-generator facility or for the acts or omissions of a Customer-generator that cause loss or injury, including death, to any third party. The Customer- generator agrees to hold the Cooperative harmless from injury or property damage incurred by any person and arising out of the ownership, operation, maintenance, or use of the parallel generation facility and to indemnify the Cooperative against all liability and expense related thereto.
  9. Prior to installing and interconnecting a Renewable Energy Resource the Customer shall enter into a standard interconnection contract with the Cooperative setting forth the conditions related to technical and safety aspects of parallel generation.
  10. Service under this rider is subject to the Cooperative's Parallel Generation Interconnection Regulations found in the Cooperative's approved rules and regulations and subsequent modifications thereto.
  11. The Customer-generator shall, at its own expense, maintain in force general liability insurance without any exclusion for liabilities related to the interconnection. The amount of such insurance shall be sufficient to insure against all reasonably foreseeable direct liabilities given the size and nature of the generating equipment being interconnected, the interconnection itself and the characteristics of the system to which the interconnection is made. For Renewable Energy Resource systems having a maximum nameplate generating capability of 10 kW or less, a Customer-generator whose system meets the standards specified in Cooperative's Parallel Generation Interconnection Regulations found in the Cooperative's approved rules and regulations shall not be required to install additional controls, perform or pay for additional tests or distribution equipment or purchase additional liability insurance other than such general liability insurance. For Renewable Energy Resource systems having a maximum nameplate generating capability of greater than 10 kW, the Cooperative's Parallel Generation Interconnection Regulations found in the Cooperative's approved rules and regulations shall: (1)

=====

Officer

Title

PRESIDENT

For Bills Rendered on or after April 1, 2024

Replacing Schedule 20 – PGS – R

Set forth safety, performance and reliability standards and insurance requirements; and (2) establish the qualifications for exemption from a requirement to install additional controls, perform or pay for additional tests or distribution equipment or purchase additional liability insurance.

12. Applications by a Customer-generator for interconnection of the qualified generation unit to the distribution system shall be accompanied by the plan for the Customer-generator's electrical generating system, including, but not limited to, a wiring diagram and specifications for the generating unit, and shall be reviewed and responded to by the Cooperative within 30 days after receipt for systems of 10 kilowatts or less and within 90 days after receipt for all other systems. Prior to the interconnection of the qualified generation unit to the Cooperative's system, the Customer-generator shall furnish the Cooperative a certification from a qualified professional electrician or engineer that the installation meets the requirements of Cooperative's Parallel Generation Interconnection Regulations found in the Cooperative's approved rules and regulations. If the application for interconnection is approved by the Cooperative and the Customer-generator does not complete the interconnection within one year after receipt of notice of the approval, the approval shall expire and the Customer-generator shall be responsible for filing a new application. Upon the change in ownership of a qualified Renewable Energy Resource, the new Customer-generator shall be responsible for filing a new application under this section.
13. The Cooperative may limit the number and size of renewable generators to be connected to the Cooperative's system due to the capacity of the distribution line to which such renewable generator would be connected.

Officer



Title

PRESIDENT

For Bills Rendered on or after April 1, 2024

Replacing Schedule 20 – PGS – R